

HKUST Net-Zero Building Standards

These standards form part of all Consultants' briefs, and the benchmarks shall be included in all contracts and subcontracts.

Application

These standards set benchmarks for the <u>minimum performance</u> for <u>new capital projects and</u> <u>major existing building alterations and additions 5000 square meters or above</u>. They shall be included in all Requests for Proposals issued and form an integral part of contracts for design consultants and contractors. The benchmarks shall be included in all contracts and sub-contracts where applicable.

First Created: 2015 (formerly known as HKUST Design Principles and High Performance Building Standards), January 2024 (HKUST Net-Zero Building Standards)

Last Reviewed: December 2024



Developed by the Sustainable Operations Executive Committee

Table of Contents

1	НКИ	ST Sustainability Objectives	3
	1.1	Mission and Vision	3
	1.2	Net-Zero Carbon Timeline	3
	1.3	Net-Zero New Construction	3
2	Scon	e of Application	4
-	Defe		
3	кеје	rence to Other HROST Policy Documents	4
4	Net-	Zero Building Requirements	5
	4.1	Elements	5
	4.2	Performance-Based Requirements for Embodied Carbon	5
	4.2.1	Approach for Embodied Carbon	5
	4.2.2	Life Cycle Analysis for Embodied Carbon	6
	4.3	Performance-Based Targets for Operational Carbon	7
	4.3.1	Approach for Operational Carbon	7
	4.3.2	Energy Modelling for Operational Carbon	8
	4.4	Performance-Based Targets for Potable Water	8
	4.5	Life Cycle Cost Analysis	8
	4.6	Independently Verified Green Building Standards (BEAM Plus)	9
	4.7	Comply-or-explain Requirements	9
	4.7.1	Approach for Comply-or-explain Requirements	9
	4.7.2	Integrated Design and Construction Management	. 10
		Sustainable Site (SDG 13: Climate Action)	. 12
	4.7.3		. 12
		Materials and Waste (SDG 12: Responsible Consumption and Production)	. 13
	4.7.4		. 13
	4.7.5	Energy Use (SDG 7: Affordable and Clean Energy) (SDG 13: Climate Action)	. 15
	4.7.6	Water Use (SDG 6: Clean Water and Sanitation)	. 17
	4.7.7	Health and Wellbeing	. 18
	4.7.8	Landscaping and Biodiversity (SDG 15: Life on Land)	. 20
	4.7.9	Energy Efficiency, Occupancy Controls and Thermal Comfort	. 21
	4.7.1	J Sustainable Smart Campus as a Living Laboratory (SDG 7: Affordable and Clean Energy)	. 23
5	Deliv	verables	25
A	nnex 1:	Net-Zero Buildings Minimum Standards Checklist	26
A	nnex 2:	Internal Price of Carbon 2020-2050	31



1 HKUST Sustainability Objectives

1.1 Mission and Vision

The Hong Kong University of Science and Technology (HKUST) strives to be a leader in sustainability, as articulated by the following sustainability mission statement:

HKUST will become a global leader in sustainability education by transforming the Clear Water Bay campus into a carbon-neutral, zero waste, and net-positive environmental impact living laboratory for experiential learning, demonstrating cutting-edge research and sustainable operations within a vibrant and engaged community.

To work towards this vision, HKUST embraces the concept of becoming a "Smart and Sustainable Campus," where our buildings and surroundings are complements to the learning environment, and where cutting-edge technologies, data, and building system information form a bridge between campus operations and learning priorities. HKUST's Smart and Sustainable Campus principles are:

- 1. Emphasize flexibility in spaces;
- 2. Anticipate future energy needs and opportunities;
- 3. Maximize potential for metering, monitoring, and sensors;
- 4. Embrace the benefits of the surroundings;
- 5. Design for social interaction; and
- 6. Integrate potential for student experimentation, research and exploration.

1.2 Net-Zero Carbon Timeline

Recognizing HKUST's net-zero commitment (See *HKUST Net-Zero Carbon Action Plan*) and support of the 2015 Paris Agreement and Hong Kong's Climate Action Plan, HKUST has made a commitment to:

- Reach a level of net-zero carbon emissions by 2045 by adopting decarbonization strategies that prioritize aggressive energy reductions, development of campus renewable energy installations, and elimination of climate-warming tracer gases and refrigerants.
- Maximize the generation of renewable energy on campus by looking to extend existing renewable energy methods and by piloting, with an aim to deploy, new types of renewable energy resources.
- Identify carbon capture and sequestration solutions to pilot with an aim towards deployment on campus.
- Use the platform, visibility, and research capacity of HKUST to support efforts of the greater Hong Kong community to reach the same this goal.
- Utilize our unique Sustainable Smart Campus as a Living Lab (SSC) framework for supporting university researchers, faculty, and staff to test innovative ideas and decarbonization measures on site for developing proof-of-concept climate solutions.

Each of these commitments are relevant to the design approaches to new construction on the HKUST campus. These H*KUST Net-Zero Building Standards* are intended to help design teams and contractors understand how to operationalize HKUST's Net-Zero commitments.

1.3 Net-Zero New Construction

Recognizing the need to support campus growth while maintaining an achievable path to net-zero, HKUST Net-Zero Carbon by 2045 Action Plan requires all new buildings to be net-zero carbon from construction stages through the end of the operational life of the building. Design consultants are expected to achieve net-zero carbon through the following four strategies:

HKUST & Sustainability

- 1. Designers are required to **provide embodied carbon assessments** for new construction. While initial embodied carbon calculations may focus on the superstructure structural elements, these requirements will be refreshed and tightened over time to reduce embodied carbon in new construction.
- 2. Design consultants and construction contractors must account for **carbon emissions created during the construction process** so they can also be included in the overall embodied carbon footprint.
- 3. All **embodied carbon emissions must be offset** by purchasing an equal number of carbon removal credits. The purchase of offsets must come from the capital budget.
- 4. New buildings must reduce energy consumption to the greatest extent possible while simultaneously maximizing renewable energy potential on-site. The **building will reach net**zero emissions when (1) the renewable generation replaces as much grid-powered electricity as possible, and (2) the revenue generated from the on-site renewables is sufficient to pay for the costs of carbon removal offsets for the remaining emissions.

2 Scope of Application

These Standards apply to all new construction and major renovations that impact a space of 5,000 square meters or above. For smaller renovations or fit outs, please refer to the *HKUST Building Renewal Standards*. This document represents the requirements of the University and expects all contractors, designers, and consultants to abide by the provisions herein.

These standards identify a minimum level of design and requirements and should be included in all Requests for Proposals issued for new projects and referenced in contracts for design consultants and construction managers.

These Standards will be periodically updated and revised.

3 Reference to Other HKUST Policy Documents

This document shall be read in conjunction with other HKUST policy documents as per **Table 1** below.

HKUST Policy Documents to be	Type 1: New	Type 2: Existing	Type 3:	Normal
Referenced	Building	Building Major	Minor	Departmental
	Construction	Renovations	Renovations	Purchases
		≥5000m ²	500 to	inside
			<5000m ²	Buildings
HKUST Net-Zero Building	Yes	Yes	-	-
Standards (this document)				
HKUST Building Renewal Standards	-	-	Yes	-
HKUST Sustainable Purchasing	Yes	Yes	-	-
Requirements				
For Suppliers and Contractors ¹				

Table 1: Applicability	of HKUST Polic	y Documents for	r Different Build	ing Related	Procurement
	ejee ee	, 2000		ing neratea	

https://sust.hkust.edu.hk/files/HKUST%20Sustainable%20Purchasing%20Contractor%20Requirements_Aug20 24.pdf



¹ HKUST Sustainable Purchasing Requirements

For Suppliers and Contractors,

HKUST Policy Documents to be	Type 1: New	Type 2: Existing	Type 3:	Normal
Referenced	Building	Building Major	Minor	Departmental
	Construction	Renovations	Renovations	Purchases
		≥5000m ²	500 to	inside
			<5000m ²	Buildings
HKUST Sustainable Office	-	-	Yes (for	Yes (for
Standards & Guidelines ²			offices)	offices)
HKUST Operation Guidelines on	-	-	-	Yes
Sustainable Purchasing for				
Departments ³				

4 Net-Zero Building Requirements

4.1 Elements

This section outlines the performance-based requirements relating to embodied and operational carbon, renewable energy as well as water consumption.

The Net-Zero building requirement comprises two elements (refer to *Figure 1*):

- 1 <u>Performance-based targets</u>, including embodied carbon in the construction process, and operational targets for energy and water post-occupancy.
- 2 <u>Comply-or-explain requirements</u> containing sustainability design strategies that shall be evaluated for each project. Non-compliance will require justification in the form of a technical feasibility study containing calculations, drawings etc.

Figure 1: Key Elements of Net-Zero Building Requirements

- Performance-based targets, including embodied carbon in the construction process, and operational targets for energy and water postoccupancy.
- Comply-or-explain requirements containing sustainability design strategies that shall be evaluated for each project. Non-compliance will require justification in the form of a technical feasibility study containing calculations, drawings etc.



4.2 Performance-Based Requirements for Embodied Carbon

4.2.1 Approach for Embodied Carbon

HKUST's strategy is to invest in the reduction of greenhouse gas emissions in all capital projects so that both embodied carbon and emissions from future operations are brought to zero, or as close as possible.

² HKUST Sustainable Office Standards & Guidelines,

https://sust.hkust.edu.hk/files/HKUSTSustainabilityGuidelinesv1.6.pdf

³ HKUST Operational Guidelines on Sustainable Purchasing,

https://sust.hkust.edu.hk/files/SustainablePurchasingOct23.pdf

Embodied Carbon Performance Target (for new buildings only):

The maximum amount of embodied carbon shall be 500 kg CO_2e/m^2 of Construction Floor Area for the superstructure portion (stages A1 to A3) as well as the construction process (stages A4 to A5). This is aligned with the latest new construction at HKUST. By 2031, this maximum amount shall include building services equipment and selected finishes, and by 2035, this will be expanded to include all interior finishes as well.

Embodied Carbon Disclosure Requirement (for new buildings and major existing building alterations and additions):

Recognizing limitations of available data, the materials required for inclusion in embodied carbon calculations will increase over time, reflecting the anticipation that LCA databases will become more robust and complete.

2023-2030	Core building and shell (superstructure including glazing, cladding, external doors and internal walls)
2031-2035	Core building and shell (superstructure), plus building services equipment, and selected finishes
2035 onward	All building elements, including interior and exterior furnishing

4.2.2 Life Cycle Analysis for Embodied Carbon

HKUST has adopted a life cycle approach to analyze the long-term costs and benefits of capital project decision-making. Assessing the embodied carbon relies on life cycle analysis to determine the overall climate impacts of building materials.

- **Software:** HKUST uses One-Click LCA and the HK Construction Industry Council Carbon Assessment Tool. Although our performance requirements only relate to stages A1 to A3 (raw material extraction and supply, transport to manufacturing plant, manufacturing and fabrication), data for stages A4 to A5 (transport to project site, construction and installation process) shall be tracked and disclosed.
- Area: The definition of "area" shall refer to construction floor area and "superstructure" shall include frame, upper floors, roofs, stairs and ramps, external walls (façade), windows and external doors, internal walls (structural and non-structural) and partitions and internal doors. Refer to RICS Whole Life carbon assessment for the built environment for further breakdown of building elements to be included.
- **Quantities:** Material quantities shall follow the project cost plan / bill of quantities, the BIM model, be estimated from drawings, or delivery receipts.
- Carbon emission factors: Carbon emission factors shall refer to database from these sources in
 order of priority 1) actual product data such as from Environmental Product Declarations or CIC
 Green Product Certification from suppliers where available, or other local generic data from 2) CIC
 Carbon Assessment Tool, or 3) OneClick LCA (use local generic data where available or next closest
 overseas generic data).
- **Submission schedule:** At the end of each design stage, calculations for embodied carbon stages A1 to A3 shall be submitted. During the construction stage, calculations for stages A1 to A5 shall be submitted every 3 months. A final as-built embodied carbon report for stages A1 to A5 shall be submitted after Occupation Permit stage.



4.3 Performance-Based Targets for Operational Carbon

4.3.1 Approach for Operational Carbon

With new buildings and major building upgrades expected to last for many decades past our 2045 netzero target, all new buildings and major upgrades must be designed to the highest efficiency level possible to reduce the carbon burden on the larger campus footprint. Since each building is unique, the performance target is simple:

Operational Performance Target:

GHG emissions from energy consumption must be offset by the revenue / avoided costs from building integrated zero carbon renewable energy production.

Figure 2: Making New Buildings / Major Upgrades Net-Zero Carbon 100% of GHG Footprint



All greenhouse gas emissions from the operations of the building over time must be offset through either the purchase of high-quality carbon offsets (in alignment with <u>The Oxford Principles for Net</u> <u>Zero Aligned Carbon Offsetting</u>) or by contributing an equal amount into an HKUST carbon reduction fund. To limit carbon offset costs, designers should maximize the amount of on-site renewables while simultaneously employing aggressive energy reduction strategies.

When the revenue from renewables equals the costs of buying offsets, HKUST considers the building to be net-zero carbon.

- Types of carbon offsets: Renewable energy shall be creatively placed to maximize the outputs
 using means such as solar panels on paving / roof trellis / car park roofs, and/or micro-turbines
 harvesting wind / kinetic / wave energy. Carbon sequestration such as biochar, algae, and/or
 carbon scrubber shall also be explored. Sub-metering shall be in place to track the renewable
 energy generated and carbon dioxide sequestered.
- **Costing assumptions:** Shadow cost of carbon offsets, earnings from renewable generation, efficiency gains, derating of equipment, feed-in-tariff rate and building life span shall be based on latest HKUST calculator.

4.3.2 Energy Modelling for Operational Carbon

- **Software:** To estimate the operation carbon, energy modelling using an ASHRAE recognized software shall be used.
- **Occupancy rate:** Occupancy rates shall be based on operating hours of the space type, reduced occupancy during school holidays, and diversity based on typical usage.
- *Weather file:* Weather file (eg. epw) used shall be based on a moderate future climate change scenario for RCP4.5 (2.7°C). This shall include temperature, humidity and solar irradiation.
- **System:** The entire building services system shall be modelled using equipment efficiency from tender and as-built stages.
- **Submission schedule:** At the end of each design stage, calculations for operational carbon shall be submitted. A final as-built operation carbon report based on as-built equipment shall be submitted after Occupation Permit stage.

4.4 Performance-Based Targets for Potable Water

The performance goal for potable water consumption shall be measured against an overall target of net-zero potable water for the building measured on an annual basis (instead of a comparison to a base building).



Figure 3: Focus on Actual Water Consumption

Designers should consider how alternative sources of water (such grey water, rainwater, A/C condensation water, filtration-reject water, and water from other reuse strategies) can be used within the building as well as outside of the building (using the campus) so that potable water consumption is offset.

Net-zero water is achieved when the total amount of alternative water produced from the building and used on campus offsets the amount of potable water consumed by the building.

4.5 Life Cycle Cost Analysis

To achieve the best value for money from a net-zero aligned perspective and recognizing the vital importance of procurement in influencing key purchasing decisions, HKUST has adopted a Life Cycle Cost Analysis (LCCA) approach to evaluating costs and benefits over time. This means:

HKUST & Sustainability

- All energy-consuming and water-consuming purchases and investments must use Life-Cycle Cost Analysis (LCCA) to ensure all associated costs of ownership, operation, and end-of-life costs are included in cost-benefit analyses.
- Utilizing an **internal carbon pricing (ICP)** to assign a cost to each ton of carbon emissions, allowing carbon considerations more central to university decision making, de-risking against the future carbon prices, and encouraging the adoption of low-carbon innovations. (*See the internal price of carbon table in Annex 2*).
- Utilizing HKUST LCCA and internal carbon pricing spreadsheets and calculators⁵ for decisionmaking.

HKUST has developed a series of training resources for practitioners in the building sector to help build skills and awareness of using life cycle analysis software, life cycle costing calculators, and other relevant materials. These resources, developed by HKUST's Life Cycle Lab⁶, are available for free, and all contractors are strongly encouraged to become familiar with them so that they can provide the life cycle information as expected by HKUST for capital projects.

4.6 Independently Verified Green Building Standards (BEAM Plus)

BEAM Plus Platinum: The Platinum Standard of performance for BEAM Plus shall apply. BEAM Plus^Z is Hong Kong's green building tools developed by Hong Kong Green Building Council. The tool covers sustainability performance criteria relating to planning, design, construction, commissioning, fitting out, management, operation and maintenance of a building, and is aligned with local regulations, standards and codes of practice. All BEAM Plus pre-requisite credit requirements must be complied with. This includes the requirement for the project demonstrate performance improvement or at least compliance based on the latest edition of Building Energy Code⁸.

4.7 Comply-or-explain Requirements

4.7.1 Approach for Comply-or-explain Requirements

Based on the pain points faced by the users of our existing buildings, these requirements encapsulate our challenges beyond carbon. These are specific built elements that go beyond standard building specifications and will become the best practice standards tailored to HKUST's needs and operational policies. They shall be evaluated for each project. Non-compliance will require justification in the form of a technical feasibility study containing calculations, drawings etc.

To align with BEAM Plus Platinum requirement and based on university priorities, the following sections reference specific BEAM Plus credits that must be met, *PLUS additional criteria to address HKUST's specific needs*.

⁵ HKUST Life Cycle Cost Calculators, https://sust.hkust.edu.hk/life-cycle-lab/contractors-and-suppliers/net-zero-online-training-module

⁶ Net-Zero Online Training Module, HKUST Life Cycle Lab, https://sust.hkust.edu.hk/life-cycle-lab/contractorsand-suppliers/net-zero-online-training-module

⁷ Hong Kong Green Building Council, BEAM Plus, https://www.hkgbc.org.hk/eng/beam-

plus/introduction/index.jsp

⁸ EMSD, Codes & Technical Guidelines,

https://www.emsd.gov.hk/beeo/en/mibec_beeo_codtechguidelines.html

4.7.2 Integrated Design and Construction Management

- a) IDCM 3 Integrated Design Process
- (a), (b), (c) Early consideration of integrated building design, buildability / constructability, operation and maintenance: Achieve 4 BEAM Plus credits for integrated design process, multi-disciplinary design charrette, early-stage consideration of buildability / constructability and design consideration for operation and maintenance.

Comply with additional criteria below:

Integrated design charrettes: At least 3 integrated design charrettes are required, the first of which should happen at the time of project kickoff and prior to the end of Schematic Design. Charrettes should include tracking of project goals and analyzing the life cycle cost impacts of potential design options. Charrettes should include representation of major stakeholders including occupants and operations staff. Project stage review reporting should include sustainability components to ensure that issues can be addressed early in the design process. It should provide an update on all elements of the standards and focus on how sustainability aspirations will be addressed through next stage review.

b) IDCM 4 Life Cycle Costing

• *Life cycle costing:* Achieve 1 BEAM Plus credit for conducting life cycle costing for active systems.

Comply with additional criteria below:

• **Energy and water consuming systems:** Include all energy-consuming and water consuming products and systems. Calculator resources and templates will be available on the HKUST Life Cycle Lab⁹ website.

c) IDCM 5 Commissioning

• (a), (b), (c), (d) Commissioning authority, review report and reports: Achieve 4 BEAM Plus credits through appointing independent commissioning authority (independent from design consultant or contractor), providing commissioning plan and commissioning review report.

Comply with additional criteria below:

- **Involvement throughout project:** A HKUST-appointed commissioning agent is required during design, construction and occupancy for all building projects, and must be present from the very beginning of the design process.
- d) IDCM 7. Measures to Reduce Site Emissions (SDG 14: Life below Water) (SDG 15: Life on Land)
- (a), (b), (c), (d) Minimization of air / noise / water / light pollution (excluding bonus credits):

Achieve 4 BEAM Plus credits for providing adequate mitigation measures during construction.

Comply with additional criteria below:

• Low carbon power supply: Where non-grid power supply is used, adopt low carbon alternatives to reduce on-site emissions and environmental impact.

⁹ HKUST Sustainability, Life Cycle Lab, <u>https://sust.hkust.edu.hk/life-cycle-lab</u>

- Water pollution mitigation: All campus construction and maintenance work must follow the University's requirements of minimizing surface runoff and preventing the discharge of dirty water into storm water drains.¹⁰
- e) IDCM 8 Construction and Demolition Waste Recycling (SDG 12: Responsible Consumption and Production) (SDG 14: Life below Water) (SDG 15: Life on Land)
- (a), (b), (c), (d) Construction and demolition waste recycling (including bonus credits): Achieve 1, plus 2 additional bonus BEAM Plus credits for 60% recycling level for construction waste and another 1, plus 2 additional bonus BEAM Plus credits for demolition waste where applicable.

• **Site waste management plan:** Provide a Site Waste Management Plan how to minimize waste and valuable resources so they are not disposed of in landfills and most waste is sorted at all stages during a construction project.

f) IDCM 9 Construction IAQ Management

- **Construction IAQ management plan and activities:** Achieve 1 credit for implementing a Construction IAQ Management Plan, undertaking a building 'flush out', and replacement of all filters prior to occupancy.
- g) IDCM 13 Digital Facility Management Interface
- **Digital interface:** Achieve 1 bonus BEAM Plus credit for providing digital interface with energy use breakdown such as energy use intensity, HVAC equipment, lifts and escalators.

h) IDCM 14 Occupant Engagement Platform

• **Digital platform:** Achieve 1 bonus BEAM Plus credit for providing a digital platform to engage building occupants.

i) IDCM 16 BIM Integration

• (a), (b) Coordinated use of BIM within design and construction teams: Achieve 1 plus 1 additional bonus BEAM Plus credit for coordinated use of BIM within Design and Construction Teams.

Comply with additional criteria below:

- Use of BIM for sustainability data: Use BIM to assist with life cycle costing, embodied carbon calculations, estimate greenhouse gas (GHG) emissions, and facilitate future measurement and verification.
- *j)* IDCM 17 Design for Engagement and Education on Green Buildings
- *Education elements (including bonus credit):* 1 additional Bonus BEAM Plus credit for providing four (4) education elements on strategies and solutions applied to the green buildings.

¹⁰ Chapter 16: Disposal of Hazardous Materials and Items under Regulatory Control, <u>https://hseo.hkust.edu.hk/sm_16</u> and

Chapter 19: Liquid Effluent and Protection of Watershed and Aquatic Environment, https://hseo.hkust.edu.hk/sm 19

 Access for research: Designers should examine the feasibility of including demonstration of embedded systems and technologies as educational projects – such as low-level renewables easily visible and accessible for students as learning tools, and available/real-time data for students to conduct analysis and study – and research projects from HKUST scholars, who can also have their projects prominently displayed to explain the theories and applications of their work.

4.7.3 Sustainable Site (SDG 13: Climate Action)

a) SS 6 Light Pollution Control

- (a) Control of obtrusive artificial light: Achieve 1 BEAM Plus credit for demonstrating that the obtrusive artificial light from exterior lighting meets the specified performance for the environmental zone in which the building development is located.
- (b) Control of external light reflection from building: Achieve 1 BEAM Plus credit for demonstrating that the sunlight reflection from external surfaces of the buildings is controlled by using materials with acceptable external light reflectance.

b) SS 8 Urban Heat Island Mitigation

- (a) Shade and high-albedo materials: Achieve 1 BEAM Plus credit for providing shade on at least 5% of the site area and at least 50% of non-roof impervious surfaces on the site (parking, walkways, plazas) using light colored high-albedo materials (albedo of at least 0.4).
- **(b)** *Tree coverage:* Achieve 2 bonus BEAM Plus credits for at least 10% of the total site area is provided with tree coverage.
- (c) Air Ventilation Assessment: Achieve 2 BEAM Plus credits for demonstrating that better or equivalent ventilation performances compared to the baseline case under annual and summer wind condition.
- (d) Intra urban heat island study: Achieve 2 bonus BEAM Plus credits for conducting an Intra Urban Heat Island Study demonstrating that a maximum Intra-Urban Heat Index in summer is less than 0.8°C.
- c) SS 9 Immediate Neighbourhood Wind Environment
- *Wind amplification:* Achieve 1 BEAM Plus credit for demonstrating that no pedestrian areas will be subject to excessive wind velocities caused by amplification due to the site layout design and/or building design.

d) SS 10 Outdoor Thermal Comfort

- (a) Shaded or covered routes: Achieve 1 BEAM Plus credit for providing at least one shaded or covered route connecting the site with nearby amenities / site main entrance / transport hub.
- (b) Passive open spaces with thermal comfort: Achieve 1 BEAM Plus credit where 50% or more of the passive open spaces and pedestrian zones achieve thermal comfort on a typical summer day at 3pm in Hong Kong.



• **Shelters minimizing direct solar radiation:** Shelters shall minimize direct solar heat gain eg. opaque. Designs shall prioritize the use of these shelters for solar energy generation.

e) SS 11 Stormwater Management

• **Stormwater management (including bonus credit):** Achieve 2 BEAM Plus credits, plus 1 additional bonus BEAM Plus credit for demonstrating that adequate stormwater management design measures have been provided to cater the total volume of runoff for one hour corresponding to a design rainfall of at least 40mm/event for the site in its post-developed conditions.

f) SS 12 Design for Climate Change Adaptation

Design for climate change adaptation (including bonus credits): Achieve 1 bonus BEAM Plus credit for studying the projected variation in temperature and rainfall and water level rise / storm surge of adjacent water bodies due to climate change and its impact on the development and prepare mitigation proposal to improve the climate resilience of the building to reduce impact from typhoons and heavy rain falls. Focus should be on below ground spaces, semi-enclosed spaces, and adjacent spaces to roof terraces / balconies. Achieve 1 additional bonus credit for including quantitative calculation to support the resilience design which is technically eligible and cost effective.

Comply with additional criteria below:

- *Extreme weather events:* Other than temperature, rainfall and water level rise / storm surge, to include forest fire, typhoons.
- **Mosquito control:** Provide mosquitoes screens for operable windows. Ensure there is well drained soil / roofs / paved surfaces to prevent water ponding during large rainfalls. If water bodies are provided, ensure no standing water. Plants chosen shall not allow water ponding on its surfaces.
- **Underground facilities:** Ensure that underground facilities are not fully enclosed to reduce risk to occupants and staff.

4.7.4 Materials and Waste (SDG 12: Responsible Consumption and Production)

- a) MW4 Design for Durability and Resilience
- (a) Building material selection appraisal: Achieve 1 BEAM Plus credit for appraisal report to evaluate durability of at least 3 building materials.
- **(b)** *Protecting vulnerable parts of the building from damage:* Achieve 1 bonus BEAM Plus credit for providing suitable protective measures to prevent damage to vulnerable parts.
- (c) Protecting exposed parts of the building from material degradation: Achieve 1 bonus BEAM Plus credit for incorporating appropriate design and specification measures to limit material degradation due to environmental factors.

b) MW 5 Sustainable Forest Products

• **Sustainable timber (including bonus credits):** Achieve 1, plus 1 additional bonus BEAM Plus credit for 100% timber and composite timber products from sustainable sources / recycled timber.



c) MW 6 Recycled Materials

- (a) Outside surface works and structures: 1 BEAM Plus credit where at least 10% of all materials used for site exterior surface works, structures and features with recycled content.
- (b) Building façade and structural components (excluding bonus credits): 1 BEAM Plus credit where at least 10% of all materials used for facade and structural components are materials with recycled content; OR the use of Pulverised Fuel Ash (PFA) as a partial cement replacement in concrete that the PFA content is not less than 25%; OR the use of Ground Granulated Blast-furnace Slag (GGBS) as a partial cement replacement in concrete that the GGBS content is not less than 40%.
- (c) Interior non-structural components (excluding bonus credits): 1 BEAM Plus credit where at least 10% of all materials used for interior non-structural components are materials with recycled content.

d) MW 7 Ozone Depleting Substances

• (a) (b) Refrigerants and ozone depleting materials: Achieve 2 BEAM Plus credits through selecting refrigerant with ozone depletion and global warming potentials within threshold, and products in building fabric and services without ozone depleting substances.

Comply with additional criteria below:

- *Refrigerants without HFC:* Refrigerants shall not contain hydrofluorocarbons (HFC).
- e) MW 8 Regional Materials
- **Regional materials (including bonus credits):** Achieve 1, plus 2 additional bonus BEAM Plus credits for using 50% or above of all building materials used in the project.

f) MW 9 Certified Green Products

• (a) Certified green products (excluding bonus credits): Achieve 2 BEAM Plus credits for having at least 5% certified green products in two (2) of the listed categories (outside surface works, building façade and structures, interior non-structural components, and building services components).

Comply with additional criteria below:

• **HKUST sustainable purchasing policies:** In compliance with HKUST Sustainable Purchasing Requirements for Suppliers and Contractors¹¹ and HKUST Operation Guidelines on Sustainable Purchasing¹².

g) MW 10 Life Cycle Assessment

• *Life cycle assessment:* 1 BEAM Plus credit for demonstrating the embodied energy in the major elements of the building structure of the building has been studied and optimized through a Life Cycle Assessment (LCA).

Refer to Section 4.2.

¹¹ HKUST Sustainable Purchasing Requirements

For Suppliers and Contractors,

https://sust.hkust.edu.hk/files/HKUST%20Sustainable%20Purchasing%20Contractor%20Requirements_Aug20 24.pdf

¹² HKUST Operational Guidelines on Sustainable Purchasing,

https://sust.hkust.edu.hk/files/SustainablePurchasingOct23.pdf

h) MW 11 Adaptability and Deconstruction

• (a) (b) Spatial adaptability and flexible engineering services (excluding bonus credits): Meet BEAM Plus credit requirements for designs providing both spatial flexibility and flexible design of services that can adapt to changes of layout and use.

Comply with additional criteria below:

• **Daylight and views:** Consider natural sunlight and views in layout of spaces, and ensure that partitions can be shifted and adjusted to maximize the views, sunlight, and natural ventilation.

4.7.5 Energy Use (SDG 7: Affordable and Clean Energy) (SDG 13: Climate Action)

- a) EU 1 Low Carbon Passive Design
- **HVAC load reduction, natural ventilation and daylight:** Achieve 4 BEAM Plus credits either using prescriptive or performance path to optimize built form orientation and spatial planning, providing external shading devices, and space layout for daylighting provision.

b) EU 2 Reduction of CO₂ Emissions

Residential Buildings

- Building envelope: Achieve 1 BEAM Plus credit for residential buildings which requires RTTV wall to be reduced by at least 10%, RTTV roof to be reduced by at least 50%, OTTV RRF, lower (if applicable) to be reduced by at least 10%, OTTV RRF, podium (if applicable) to be reduced by at least 40%.
- **Natural ventilation:** Achieve 2 BEAM Plus credits for at least 40% of normally occupied space (habitable space) to satisfy the ventilation requirements.

Non-Residential Buildings

• **Building envelope:** Achieve 1 BEAM Plus credit for OTTV non-residential tower to be reduced by at least 10%, OTTV non-residential podium to be reduced by at least 40%.

Comply with additional criteria below:

- *Window / door frames:* To provide thermal breaks at window / door frames to mitigate heat gain, and weatherstripping to minimize air infiltration.
- **Roof:** To provide coating with high Solar Reflectance Index and achieve U-value performance to meet ASHRAE 90.1-2016.
- *Glazing*: To achieve U-value performance to meet ASHRAE 90.1-2016.

Refer to Section 4.3.

- c) EU 3 Peak Electricity Demand Reduction
- **Reduction of peak electricity:** Achieve 3 BEAM Plus credits for at least 15% reduction of peak electricity demand.

Comply with additional criteria below:

• **Reduction of peak electricity demand charge:** Adopt low carbon solutions (e.g. energy storage) to reduce peak electricity demand charge. Consider battery back-up power options instead of gensets to allow for more flexibility in utilizing load shifting strategies.

Refer to Section 4.3.

HKUST **b** Sustainability

d) EU 4 Metering and Monitoring

• (a), (b) Fundamental metering and monitoring / metering for tenanted areas (including bonus credits): Achieve 1 plus 2 bonus BEAM Plus credits for providing energy monitoring system and performance auditing monitoring system for equipment and systems in spaces, and allowing monitoring provision of tenants' energy consumption.

Comply with additional criteria below:

- **Fundamental metering and monitoring / metering:** Provide energy monitoring system and performance auditing monitoring system for equipment and systems in spaces, and allowing monitoring provision of energy consumption.
- Energy consumption monitoring: Provide power metering system to track power usage for different aspects such as air conditioning, lighting and equipment. Sub-meters for major energy consuming equipment eg. lab fridges and equipment, and renewable systems shall be provided. Electricity and cooling sub-metering shall allow user charging on a lab/room/zone based on future user allocation.
- Access for research: Ensure meters are in place, pipework is accessible, and data and dashboard are open source to facilitate research by researchers and students. Data shall have the ability to be seen and downloaded by all interested users (students, faculty, and FMO staff).
- **Usage pattern:** Design for sensors and people counters so that the building can track the flow of people coming and going at different times of the days, and integrate the data into building management, security, and space optimization strategies.

e) EU 8 Energy Efficient Appliances

• **Certified electrical appliances:** Achieve 2 BEAM Plus credits for having more than 80% total rated power of appliances certified Grade 1 under Mandatory and Voluntary Energy Efficiency Labelling Scheme for residential buildings.

Comply with additional criteria below:

- Certified electrical appliances and lab equipment: For <u>all buildings</u>, have 100% of appliances and lab equipment certified Grade 1 under Mandatory and Voluntary Energy Efficiency Labelling Scheme, or most energy efficient rating of an equivalent certification scheme for electrical equipment. Refer to HKUST Sustainable Purchasing Requirements for Suppliers and Contractors¹³ and HKUST Operation Guidelines on Sustainable Purchasing¹⁴.
- Fume cupboards: All fume cupboards should be equipped with auto sash function for energy saving. All new fume cupboard should be equipped with combination sash which can be open both vertically and horizontally. Both vertical and horizontal sash position should be able to interface with the VAV system to control the flow rate.

¹³ HKUST Sustainable Purchasing Requirements

For Suppliers and Contractors,

https://sust.hkust.edu.hk/files/HKUST%20Sustainable%20Purchasing%20Contractor%20Requirements_Aug20 24.pdf

¹⁴ HKUST Operational Guidelines on Sustainable Purchasing,

https://sust.hkust.edu.hk/files/SustainablePurchasingOct23.pdf

4.7.6 Water Use (SDG 6: Clean Water and Sanitation)

- a) WU 1 Annual Water Use, WU 3 Water Efficient Appliances and WU 7 Effluent Discharge to Foul Sewers
- (a) (b) Potable water reduction: (including bonus credits) Achieve 3 plus 1 additional bonus BEAM Plus credit for at least 40% annual water savings.
- *Water efficient appliances:* Achieve at least 1 BEAM Plus credit for washing machines provided in all residential units to be at least Grade 1 under WELS standard.
- **Sewerage volume reduction:** Achieve 1 BEAM Plus credit for reduction in annual sewage volumes by 20% or more.

Comply with additional criteria below:

- Water efficient appliances, sanitary fittings and lab equipment: All facilities should meet Hong Kong Water Efficiency Labelling Scheme¹⁶ (WELS) Grade 1 standard for equipment, or US-EPA WaterSense¹⁷ criteria if there is no WELS standard.
- *Water use sub-metering:* Water consumption sub-metering for potable and non-potable water uses separately (separate lab and non-lab) shall be provided.

Refer to HKUST Sustainable Purchasing Requirements for Suppliers and Contractors¹⁸ and HKUST Operation Guidelines on Sustainable Purchasing¹⁹.

b) WU 2 Water Efficient Irrigation

• **No potable water for irrigation (including bonus credit):** Achieve 2 plus 1 additional bonus BEAM Plus credit for 100% reduction in potable water consumption for irrigation.

Comply with additional criteria below:

- *Water efficient planting:* Native species and/or drought-tolerant plants shall be adopted to minimize water use.
- *Water use monitoring:* Water consumption sub-metering for irrigation shall be provided.

c) WU 3 Water Efficient Appliances

 Water efficient appliances: Achieve 1 BEAM Plus credit for installing water efficient appliances that achieve Grade 1 under the WSD's Water Efficiency Labelling Scheme for residential buildings.

Comply with additional criteria below:

• For <u>all buildings</u>, have 100% of appliances certified Grade 1 under WSD's Water Efficiency Labelling Scheme, or most water efficient rating of an equivalent certification scheme for water consuming equipment.

¹⁶ Water Supplies Department, Water Efficiency Labelling Scheme (WELS),

https://www.wsd.gov.hk/en/plumbing-engineering/water-efficiency-labelling-scheme/index.html

¹⁷ EPA, The WaterSense Label, https://www.epa.gov/watersense/watersense-label

¹⁸ HKUST Sustainable Purchasing Requirements

For Suppliers and Contractors,

https://sust.hkust.edu.hk/files/HKUST%20Sustainable%20Purchasing%20Contractor%20Requirements_Aug20 24.pdf

¹⁹ HKUST Operational Guidelines on Sustainable Purchasing,

https://sust.hkust.edu.hk/files/SustainablePurchasingOct23.pdf

- Refer to HKUST Sustainable Purchasing Requirements for Suppliers and Contractors²⁰ and HKUST Operation Guidelines on Sustainable Purchasing²¹.
- *Pipe water refilling system:* Install a pipe filtration water refilling system to eliminate the use of bottled water.

d) WU 6 Cooling Tower Water

• **Cooling tower water use:** Achieve 1 BEAM Plus credit for achieving 7 or more cycles of concentration with acceptable water quality.

Comply with additional criteria below:

- *Water use monitoring:* Water consumption sub-metering for cooling tower including makeup and blowdown lines shall be provided.
- *Water loss controls:* Measures to eliminate water loss from drift.
- *Water usage controls:* Sensors and automated controls to control water use based on actual requirements.

e) WU 8 Water Harvesting and Recycling

• (a), (b) Water reuse (including bonus credit): Achieve 2 BEAM Plus credits, plus 1 bonus BEAM Plus credit for harvested rainwater and recycled grey water to achieve at least 10% or more potable water reduction.

Comply with additional criteria below:

- Air conditioning condensate water reuse: Condensate water from air conditioning systems is not allowed to go into the sewer or wastewater piping. Water derived from air conditioning condensation can be used for irrigation, toilet flushing, or other grey water purposes. Further, since the temperature of the water is generally colder than general potable water, effort should be made to recycle the water into cooling towers or other means for exchanging heat. Sub-metering shall be in place to track water reuse.
- **Other water reuse:** Rainwater and cooling tower bleed-off reuse shall be maximized wherever possible. Sub-metering shall be in place to track water reuse.

Refer to Section 4.4.

4.7.7 Health and Wellbeing

- a) HWB 1 Healthy and Active Living
- *Healthy and active elements (including bonus credit):* Achieve 1 bonus BEAM Plus credit for at least 3 items of all applicable design measures for healthy and active living.

²⁰ HKUST Sustainable Purchasing Requirements

For Suppliers and Contractors,

https://sust.hkust.edu.hk/files/HKUST%20Sustainable%20Purchasing%20Contractor%20Requirements_Aug20 24.pdf

²¹ HKUST Operational Guidelines on Sustainable Purchasing,

https://sust.hkust.edu.hk/files/SustainablePurchasingOct23.pdf

Introducing biophilic design and healthy and active elements have been shown to enhance the productivity of the work / study environment, while improving the health of building occupants. During the development of the brief with the building occupants, propose and evaluate the following features:

- Open layout workstations & flexible and multi-purpose enclosed rooms: Consider open layout workstations to facilitate communication, while using furniture / plants to define zones. Work station partitions shall be kept low, while use of glass walls / doors / windows shall be optimized. Enclosed rooms shall be placed in the center to maximize natural daylight and view sightlines for the majority of the users.
- **Inclusions of plants:** For spaces with regular occupants, consider designating areas for indoor plants.
- **Designated active workstations:** Consider using active workstations in selected workspaces eg. standing desks equipped with walking pads and bicycle-desk hybrid workstation.
- **Choice of colors:** For the colors of the walls, carpet and interior finishing, engage users to select calming color tones preferred by the users and/or aligned with the department's branding.
- **Circadian lighting system:** Use this lighting system in working areas (eg. rooms without access to daylight) whereby users will benefit from being aligned to the human circadian rhythm by mimicking the color temperature and intensity of natural sunlight throughout the day.

b) HWB 6 Acoustics and Noise

• (a), (b) Room acoustics, noise isolation and background noise (including bonus credits): Achieve 4 BEAM Plus credits, plus 1 bonus BEAM Plus credit for meeting the prescribed acoustic criteria for the prescribed spaces.

c) HWB 7 Indoor Vibration

• *Vibration levels:* Achieve 1 BEAM Plus credit for demonstrating vibration levels not exceeding the prescribed criteria.

d) HWB 8 Indoor Air Quality

• (a), (b) Indoor air quality in occupied space and car park: Indoor air quality testing for occupied spaces to meet IAQ Certification Scheme (Good Class) certificate issued by the Environmental Protection Department (EPD). Car park air quality to comply with the pollutant concentration limits specified in ProPECC PN 2/96.

Comply with additional criteria below:

 Low emitting materials: Paints, adhesives, furniture and furnishing shall be in compliance with HKUST Sustainable Purchasing Requirements for Suppliers and Contractors²² and HKUST Operation Guidelines on Sustainable Purchasing²³. This shall include built-in furniture and fixture, loose furniture and carpet.

²² HKUST Sustainable Purchasing Requirements

For Suppliers and Contractors,

https://sust.hkust.edu.hk/files/HKUST%20Sustainable%20Purchasing%20Contractor%20Requirements_Aug20 24.pdf

²³ HKUST Operational Guidelines on Sustainable Purchasing,

https://sust.hkust.edu.hk/files/SustainablePurchasingOct23.pdf

e) HWB 10 Lighting Quality

• (a) (b) Artificial lighting in normally occupied spaces and not normally occupied spaces / unoccupied spaces: Achieve 2 BEAM Plus credits for meeting minimum standards for illuminance, illuminance uniformity, unified glare rating and color rendering index as per the latest CIBSE's Code for Lighting.

4.7.8 Landscaping and Biodiversity (SDG 15: Life on Land)

Trees on the campus landscape of HKUST are some of the most valuable resources of the property, and a key to the attractiveness and beauty to our campus residents and to outsiders. They also have biological and biodiversity value. HKUST places a priority on growing and maintaining campus trees as valuable assets.

- Prioritization of brownfield site: HKUST is a relatively young university, with the oldest buildings being only around 30 years old. The land area granted by the Hong Kong government for HKUST campus is a greenfield site surrounded by mostly undeveloped areas. Where future brownfield sites may exist within the allocated land, the project team shall prioritize the evaluation of these sites for constructing future buildings.
- Site ecology: Demonstrate how to enhance the ecological value of the site. Adopt measures such as use of surface water, native and edible planting, avoidance of polluting treatments and materials, avoid need for irrigation. The design team must show evidence of how plants and trees are used as part of a wider ecological strategy including solar shading and water processing and retention for "sponge city" benefits. There are a range of opportunities to integrate natural environment with overall building ecology providing amenity and environmental benefits.
- **No chemical fertilizer policy:** Use organic fertilizer instead of chemical fertilizer to reduce water pollution and as part of watershed management.
- Existing plant protection: For plants on existing sites, identify, monitor and protect plant species listed in the IUCN Red List, Forestry Regulations Cap. 96A²⁴, and Protection of Endangered Species of Animals and Plants Ordinance Cap. 586 (Schedule 1)²⁵ to ensure their preservation and promote species recovery, particularly Diospyros vaccinioides.
- Land conservation and restoration: Use land sustainably through conservation and restoration. Implement compensatory planting proposal of a ratio not less than 1:1 in terms of number as per Lands Department mandatory requirements for preparing Tree Preservation and Removal Proposal²⁶, preferably within the existing site boundary. If constraint by space, compensatory planting shall be in a suitable location within HKUST boundary. Consider height of compensatory trees in ways that maximize their value on campus *e.g., small trees should be used where we want to preserve sight lines to the waterfront, and larger shade trees around pathways and roadways.
- **Native species:** Prioritize native species (more than 50%) in planting and landscaping to maximize the local biodiversity included in planning and development projects through enhancing ecological value of the landscape and providing habitat and food sources for local wildlife.
- *Invasive species:* Control the impact of alien species, especially avoiding invasive ones, to prevent disruptions to ecosystems and maintain the natural balance.

²⁴ Forestry Regulations (Cap. 96, section 3), GovHK, https://www.elegislation.gov.hk/hk/cap96A

 $^{^{\}rm 25}$ Cap. 586 Protection of Endangered Species of Animals and Plants Ordinance,

https://www.elegislation.gov.hk/hk/cap586?xpid=ID_1438403490651_001

²⁶ Lands Department, Guidance Notes on Tree Preservation and Removal Proposal for Building Development in Private Projects – Compliance with Tree Preservation Clause under Lease,

https://www.landsd.gov.hk/doc/en/practice-note/lpn/PN%206_2023%20Guidance.pdf

- **Plants with dual purpose:** New plants have more purposes than one. Investigate areas of planting and landscaping for productive uses. Certain plants are useful for absorbing VOCs and other airborne contaminants, while others are exceptional at releasing oxygen at specific times of the day. Vertical planting on south-facing walls and trees with dense canopies can absorb solar heat during summer months. Bamboo with its high growth rates is good for biochar, carbon sequestration and furniture.
- **Existing saplings:** Where available, existing saplings of native species and exotic species with value shall be transplanted to a suitable site in HKUST.
- **Wood utilization:** Consider the value of trees at the end of their lifespan for lumber use in HKUST projects. Trees felled shall not be in good health and have good amenity value, and shall be cut and sorted for maximum reuse. Tree felling contracts shall meet the below requirements:
 - A crane should be provided to transport 2m long tree trunk / branches to the road, for ease of delivery off-site to HKUST's designated recycler. This allows maximum reuse into timber furniture and interiors.
 - The tree felling contractor should have some experience with tree felling for purposes of manufacturing timber planks for reuse into timber furniture or interior works.
 - Requirements of size of tree logs
 - Cut lines shall be as close to the bottom of trunk as possible, around 100mm from the ground level.
 - The form of the tree fork shall be kept.
 - Wood logs shall be kept not less than 1.5 meters long, preferably over 2m.
 - Curved part shall be cut through to keep the wood log straight.
 - The length of the wood log should not exceed the container length of the grab lorry / crane lorry.
 - All other smaller diameter tree branches (under 200mm diameter) should be sent to Y-Park for recycling.
- **Exposed services:** Pipework shall always be buried to maximize ground area for other usage.

4.7.9 Energy Efficiency, Occupancy Controls and Thermal Comfort

To achieve net-zero, energy efficiency is the utmost important. Equipment selection needs to be the most energy efficient in the local market. Opportunities for further energy savings are presented at HKUST owning to its variability of usage during term time and term break. Flexibility in building services controls also needs to be ensured due to frequent changes in space usage during the lifespan of the building, as well as operation hours. Occupancy controls for ventilation, cooling and lighting shall have overwrite function for always on during occupancy, and facilitating partial use of the space, and reduced occupancy during school holidays.

Cooling & Ventilation Equipment

• **Equipment efficiency:** Meet minimum standards for building services equipment as per ASHRAE 90.1-2016 and/or latest version of Building Energy Code, whichever is more stringent.



- **Fan-enhanced ventilation:** For air-conditioned spaces (except protected areas), enhanced ventilation shall be provided to increase temperature set points for energy savings, reduce condensation risk and cater to varying user requirements to enhance thermal comfort satisfaction (eg. through mechanical or ceilings fans). An example and demonstration of such fan in the HKUST Sustainability Office may be accessed here.²⁷
- **Entryway infiltration control:** At entryways, balconies, lift shafts, and staircases, adopt vestibules, infiltration control and/or airlocks to prevent humid air entering and cooled air escaping.
- *Variable equipment:* Equipment shall be variable air volume or flow to allow occupancy controls.
- *Energy recovery and demand control equipment:* Equipment shall have heat recovery and demand control ventilation.
- *Mold growth and condensation prevention:* Introduce adequate ventilation for staircases, lobbies, corridors to prevent mold growth and condensation.

Cooling & Ventilation Controls

- **Room pressure and temperature:** Room temperature is suggested to be kept at a user agreed value when occupied and not exceed 28°C (adjustable) when unoccupied to maintain a min. flow set point for VAV boxes, unless specified otherwise. No space heating for winter. Relative humidity below 70% unless specified otherwise.
- *Air change:* Provide a user agreed minimum air change rate for occupied periods, and a user agreed reduced amount during unoccupied periods. Recirculation of air is allowed unless otherwise specified.
- **General timer control:** Controls for teaching facilities shall follows classroom schedule as per ARO, and all other areas shall follow CMO schedule. Overwrite function shall be provided with the local zone occupancy controls below.
- Local occupancy control for specified zones: When there is no occupancy detected at a certain zone, the zone's VAV box will be adjusted so that the damper position will reduce the airflow rate to an agreed minimum. Once occupancy is detected, the damper will revert back to 100% open. Zoning allocation shall be agreed with building users.
- Window interlock: Provide a window contact system that will interface with cooling and ventilation system. For inner zones, set back temperature to 28°C. For small rooms, cooling will be switched off and fan speed set to the minimum.

Lighting Equipment

- Lighting power density: The total lighting power shall follow the latest edition of Building Energy Code (BEC) or CIBSE standards whichever is more stringent.
- **Task lighting provision:** Task lighting, coupled with occupancy sensor, to be installed in addition to room lighting.
- **Switch & sensor provision:** On/off switch, dimming switch and occupancy / motion sensor should be provided. Daylight dimmers with at least 10 stages of dimming to match daylight levels to be provided for labs, lift lobby, staircase and toilets with glazed windows.

²⁷ HKUST Sustainability / Net-Zero Office, Sustainability Office Features, Green Technology, Energy-Saving Bladeless Fans to Reduce Need for Air-Conditioning, https://sust.hkust.edu.hk/greentechnology

Lighting Control

- **General timer control:** Controls for teaching facilities shall follows classroom schedule as per ARO, and all other areas shall follow CMO schedule. Overwrite function shall be provided with the local zone occupancy controls below.
- **Task lighting control:** Task lighting (by work area) should be controlled with occupancy sensors (DC connection) or manually by users. Color temperature is around 4000K. When turned on at 100%, the actual lumens should be meet design levels for the space type at 900mm from floor when combined with room lighting. The time delay for turning off task lighting should be 18 to 360 seconds (adjustable).
- **General lighting control:** Lighting controls should help save energy by limiting either the time lights are on or the power they are drawing or both. Zoning allocation shall be agreed with building users.

The time delay for turning off lights should be:

- If there is no occupation for a certain zone, zonal lighting can be dimmed smoothly in 3 stages from the designed lighting level to 30% to 0% (off).
- Once occupancy is detected, lighting should resume smoothly to the designed lighting level.

4.7.10 Sustainable Smart Campus as a Living Laboratory (SDG 7: Affordable and Clean Energy)

HKUST's campus as a "Living Lab" helps to facilitate home-grown novel solutions and proofs of concept for net-zero approaches and technologies. The Living Lab approach will transform our campus into a testing ground for ambitious solutions that will support our Net-Zero goal. The near-term deliverables will be the development of a framework for HKUST researchers, faculty, and staff to test innovative ideas and decarbonization measures focused on energy conservation measures, renewable energy generation, and carbon removal and sequestration.

It is HKUST's expectation that design consultants will, from time to time and when requested, work with HKUST research teams to explore how new research approaches can be integrated into new building designs.

Examples of HKUST research that may be relevant in the design process:

- **Decarbonization research and development:** HKUST has teams working on the development and application of decarbonization through small scale introduction of the following technologies:
 - Carbon storage in materials eg. biochar blocks, carbon dioxide embedded pavers / blocks / reinforced concrete, bamboo or other timber;
 - Carbon dioxide scrubber;
 - Carbon sequestration eg. biochar, algae, bamboo; and
 - Direct air capture.
- **Future renewable provision:** Anticipating that all exterior surfaces (including vertical surfaces, windows, and doors) that have solar exposure will be utilized in the future for energy generation, HKUST researchers are actively exploring new techniques. Design consultants should incorporate in conduit channels and other means for making it easy to access these areas for electrical wiring, and ensure structural loading is sufficient for future solar panel additions.
- Lower current power systems for renewables: Considering an emerging area of research looking at how buildings may be converted to be DC powered for greater efficiency, design consultants



shall consider how to isolate certain systems (e.g., lighting) so that they can be served by lower current power systems (e.g. direct current) as renewables are added to the building.



5 Deliverables

Checks are in place throughout the building project stages to ensure that the minimum standards can be met. Refer to *Table 2* below. This facilitates the building of a database to allow future sustainability performance to be benchmarked and targets to be set.

Table 2: Submission of Sustainability Data Throughout Building Project Stages

Building Project Stages	Submission Deliverables					
Request for Fee Proposal	• Approach and strategy on how performance requirements for					
(By Consultants)	operational carbon and renewable energy can be met.					
	Approach and strategy on how performance requirements for					
	stages A1 to A3 embodied carbon can be met.					
	• Approach and strategy on how net-zero water use can be met.					
Schematic Design	the end of each design stage					
	• Design calculations with supporting documentation to					
Detail Design	demonstrate compliance to performance-based requirements.					
	To include operational carbon, stages A1 to A3 embodied carbon,					
Tender Documentation	and net-zero water use. (At the end of each design stage)					
(By Consultants)	• Design checklists to explain how the requirements are					
	incorporated in the design.					
	• Life cycle costing for energy-consuming & water-consuming					
	products & systems					
Construction Stage	Monthly					
(By Main Contractor)	• Electricity consumption and renewable energy per month (kWh					
	per month)					
	• Water consumption and water reused per month (m ³ per month)					
	• Waste generation and waste recycled per month (tonnes or kg					
	per month for each type of waste)					
	Every quarterly					
	 Stages A1 and A5 embodied carbon calculations 					
Occupation Permit	Within 3 months of obtaining Occupation Permit					
(By Main Contractor)	• As-built calculations with supporting documentation to					
	demonstrate compliance to performance-based requirements.					
	To include operational carbon, stages A1 to A5 embodied carbon					
	and net-water use.					
	• As-built checklists to explain how the requirements are					
	incorporated in the as-built design.					



Annex 1: Net-Zero Buildings Minimum Standards Checklist

The requirements presented in this document is summarized in the form of a checklist for ease of reference by the consultant and construction teams, as well as for compliance checks by HKUST. A completed checklist shall be submitted at the end of each design stage and within 3 months of obtaining Occupation Permit.

No.	Requirement	Ref.	Adopted	Remarks			
		Section in	(Y/N/NA)				
		Document					
	Performance-Based Targets						
	Achieves performance goals listed below.						
1	(a) Max. embodied carbon 500 kg	4.2					
	CO ₂ e/m ² of CFA for superstructure						
	(stages A1 to A3) (for new buildings).						
	(b) Embodied carbon disclosure						
	requirement (for new buildings and						
	major existing building alterations						
	and additions).						
2	≥7.5% renewable energy to generate	4.3					
	revenue to offset cost of carbon.						
3	Annual alterative water source	4.4					
	offsets annual potable water						
	consumption.						
4	Life cycle cost analysis	4.5					
5	BEAM Plus Platinum standard.	4.6					
	Comply-or-Ex	plain Require	ements				
Сс	omply with the requirements listed below	. If not adopt	ed, justifica	tion shall be given using			
	technical feasibility study contain	ing life cycle	calculations	, drawings etc.			
Integr	rated Design and Construction Managen	nent	[
6	BEAM Plus credit IDCM 3 (a), (b), (c),	4.7.2 (a)					
	plus additional criteria for integrated						
	design charrettes.						
7	BEAM Plus credit IDCM 4, plus	4.7.2 (b)					
	additional criteria for energy and						
	water consuming systems.						
8	BEAM Plus credit IDCM 5 (a), (b), (c),	4.7.2 (c)					
	(d), plus additional criteria for						
	commissioning agent involved						
	throughout project.	470(1)					
9	BEAM Plus credit IDCM 7 (a), (b), (c),	4.7.2 (d)					
	(d) (excluding bonus credits), plus						
	additional criteria for low carbon						
	power supply and waste pollution						
10		472()					
10	BEAN Plus credit IDUN 8 (a), (b), (c),	4.7.2 (e)					
	(u) (including bonus credits), plus						
	auditional criteria for site Waste						
11		472/5					
111	BEAIVI PIUS CLEAIT IDCIVI 9.	4./.Z (T)					



No.	Requirement	Ref.	Adopted	Remarks
		Document		
12	REAM Plus credit IDCM 12	4.7.2 (g)		
12	BEAM Plus credit IDCM 14	4.7.2 (g)		
14	BEAM Plus credit IDCM 16 (a) (b)	4.7.2 (1)		
14	BEAN Plus credit IDCN 10 (d), (D),	4.7.2 (1)		
	for sustainability data			
15	BEAM Plus credit IDCM 17 (including	4 7 2 (i)		
13	bonus credit) plus additional criteria	4.7.2 (J)		
	for access for research			
Sustai	inable Sites	I	L	
16	BEAM Plus credit SS 6 (a). (b)	4.7.3 (a)		
17	BEAM Plus credit SS 8 (a) (b) (c) (d)	473(b)		
1,	(including bonus credits)	ч.7.5 (б)		
18	BEAM Plus credit SS 9.	4.7.3 (c)		
19	BEAM Plus credit SS 10 (a), (b), plus	4.7.3 (d)		
	additional criteria for shelters			
	minimizing direct solar radiation.			
20	BEAM Plus credit SS 11 (including	4.7.3 (e)		
	bonus credit).			
21	BEAM Plus credit SS 12 (including	4.7.3 (f)		
	bonus credits), plus additional criteria			
	to extreme weather events, mosquito			
	control, and underground facilities.			
Mater	rials & Waste	ſ		
22	BEAM Plus credit MW 4 (a), (b), (c)	4.7.4 (a)		
	(including bonus credits).			
23	BEAM Plus credit MW 5 (including	4.7.4 (b)		
	bonus credit).			
24	BEAM Plus credit MW 6 (a), (b), (c) (excluding bonus credits).	4.7.4 (c)		
25	BEAM Plus credit MW 7 (a), (b), plus	4.7.4 (d)		
	additional criteria for refrigerants			
	without HFC.			
26	BEAM Plus credit MW 8 (including	4.7.4 (e)		
	bonus credits).			
27	BEAM Plus credit MW 9 (excluding	4.7.4 (f)		
	bonus credits), plus additional criteria			
	for HKUST sustainable purchasing			
	policies.			
28	BEAM Plus credit MW 10.	4.7.4 (g)		
29	BEAM Plus credit MW 11 (a), (b)	4.7.4 (h)		
	(excluding bonus credits), plus			
	additional criteria for daylight and			
Free and F ree				
20	PEANA Dlug gradit ELL 1 (LIVAC load	175(0)		
50	reduction natural ventilation and	4.7.3 (d)		
	daylight)			
	uayiigiit <i>i</i> .			



No.	Requirement	Ref. Section in Document	Adopted (Y/N/NA)	Remarks
31	BEAM Plus credit EU 2 (building envelope for residential and non- residential buildings, and natural ventilation for residential building only), plus additional criteria for window / door frames, roof and glazing.	4.7.5 (b)		
32	BEAM Plus credit EU 3, plus additional criteria for reduction of peak electricity demand charge.	4.7.5 (c)		
33	BEAM Plus credit EU 4 (a), (b) (including bonus credits), plus additional criteria for energy consumption monitoring, function and location, access for research, and usage pattern.	4.7.5 (d)		
34	BEAM Plus credit EU 8 (2 credits), plus additional criteria for 100% of appliances to be certified Grade 1, and fume cupboards.	4.7.5 (e)		
Water	r Use			
35	BEAM Plus credit WU 1, WU 3, WU 7 (including bonus credit), plus additional criteria for toilets and water use monitoring.	4.7.6 (a)		
36	BEAM Plus credit WU 2 (including bonus credit), plus additional criteria for water-efficient planting and water use sun-metering.	4.7.6 (b)		
37	BEAM Plus credit WU 3, plus additional criteria for 100% of appliances to be certified Grade 1 and pipe water refilling system.	4.7.6 (c)		
38	BEAM Plus credit WU 6, plus additional criteria for water use monitoring, water loss, and water use controls.	4.7.6 (d)		
39	BEAM Plus credit WU 8 (a), (b), (including bonus credit), plus additional criteria for air-conditioning condensate water reuse and other water reuse.	4.7.6 (e)		
Health	n and Wellbeing	4774		
40	BEAM Plus credit HWB 1 (including bonus credit).	4./.7 (a)		
41	BEAM Plus credit HWB 6 (a), (b), (c) (including bonus credit)	4.7.7 (D)		
42	BEAM Plus credit HWB 7.	4.7.7 (c)		



No.	Requirement	Ref. Section in Document	Adopted (Y/N/NA)	Remarks
43	BEAM Plus credit HWB 8 (a), (b), plus	4.7.7 (d)		
	additional criteria for low emitting-			
	materials.			
44	BEAM Plus credit HWB 10 (a), (b).	4.7.7 (e)		
Lands	caping and Biodiversity			
45	Prioritization of brownfield site	4.7.8		
46	Site ecology			
47	No chemical fertilizer policy			
48	Existing plant protection			
49	Land conservation and restoration			
50	Native species			
51	Invasive species			
52	Plants with dual purpose			
53	Existing saplings			
54	Wood utilization			
55	Exposed services			
Energ	y Efficiency, Occupancy Controls and The	ermal Comfo	rt	
56	Cooling & ventilation equipment:	4.7.9		
	Equipment efficiency			
57	Cooling & ventilation equipment:			
	Fan-enhanced ventilation			
58	Cooling & ventilation equipment:			
	Entryway infiltration control			
59	Cooling & ventilation equipment:			
	Variable equipment			
60	Cooling & ventilation equipment:			
	Energy recovery and demand control			
	equipment			
61	Cooling & ventilation equipment:			
	Mold growth and condensation			
	prevention			
62	Cooling & ventilation controls: Room			
62	pressure and temperature			
63	cooling & ventilation controls: Air			
64	Cooling & vontilation controls:			
04	Cooling & ventilation controls.			
65	Cooling & ventilation controls: Local			
05	occupancy control for specified zones			
66	Cooling & ventilation controls:			
	Window interlock			
67	Lighting equipment: Lighting power			
	density			
68	Lighting equipment: Task lighting			
	provision			
69	Lighting equipment: Switch & sensor	1		
	provision			



No.	Requirement	Ref.	Adopted	Remarks
		Document		
70	Lighting control: General timer			
	control			
71	Lighting control: Task lighting control			
72	Lighting control: General lighting			
	control			
Sustai	nable Smart Campus as a Living Laborat	ory		
73	Decarbonization research and	4.7.10		
	development			
74	Future renewable provision			
75	Lower current power systems for			
	renewables			



Annex 2: Internal Price of Carbon 2020-2050

The Internal Price of Carbon (IPC) is an important tool for determining the collection and reallocation of funding based on greenhouse gas emissions due to operations. The IPC should also be used by contractors and design teams to establish costs for comparison in decision-making. Pricing references the Net Zero by 2050 scenario in IEA's Global Energy and Climate (GEC) Model. Pricing is specifically for emerging market and developing economies with net-zero emissions pledges, which includes China, India, Indonesia, Brazil and South Africa.

Year	IEA Carbon Price	HKUST Carbon Price
	(USD/Ton)	(HKD/Ton)
2020	\$30	\$ 235
2021		\$ 255
2022		\$ 280
2023		\$ 300
2024		\$ 325
2025		\$ 350
2026		\$ 420
2027		\$ 490
2028		\$ 560
2029		\$ 630
2030	\$90	\$ 700
2031		\$ 755
2032		\$ 810
2033		\$ 865
2034		\$ 920
2035		\$ 975
2036		\$1,030
2037		\$1,085
2038		\$1,140
2039		\$1,195
2040	\$160	\$1,250
2041		\$1,281
2042		\$1,312
2043		\$1,343
2044		\$1,374
2045		\$1,405
2046		\$1,436
2047		\$1,467
2048		\$1,498
2049		\$1,529
2050	\$200	\$1,560

Internal Price of Carbon for HKUST

